

Nisource C/O Cory Rector  
Meter Shop  
5315 Fisher Road  
Columbus, Ohio 43228

M-2024-3047438- jbs 3/2/26

Robert Horensky, Manger  
Safety Division  
Bureau of Investigation and Enforcement  
Pennsylvania Public Utility Commission  
PO Box 3265  
Harrisburg, PA 17105-3265

Robert Horensky  
Safety Division  
Bureau of Investigation and Enforcement  
Pennsylvania Public Utility Commission  
PO Box 3265  
Harrisburg, PA 17105-3265

February 26, 2026

Greetings,

Enclosed are reports on the Columbia Gas of Pennsylvania's 2025 Meter Sampling program for Class A, B and C meters.

The Class A meters followed the same statistical sampling plan as in previous years and completed the required number of meter removals and tests.

The 2025 Class B and Class C variable interval program did not complete the required number of removals. All meters in the Class B and C Miscellaneous families are retired from service once they are removed.

I hope this presents an understandable summary of Columbia Gas of Pennsylvania's meter testing program. Please feel free to contact me if you require any further information.

Cory Rector  
Meter Shop Manager  
Cell: 937-561-2693  
crector@nisource.com

### CLASS A METER PROGRAM - STATISTICAL

MANUFACTURER	INSTALLED	REQUIRED REMOVALS	TOTAL REMOVED	FAILURE RATE
AMERICAN	287,818	800	3062	14%
ROCKWELL	59,972	500	1,663	16%
NATIONAL	24,600	315	590	6%
SPRAGUE	37,618	500	568	8%

### CLASS B & C METER PROGRAM – VARIABLE INTERVAL

MANUFACTURER	INSTALLED	REQUIRED REMOVALS	TOTAL REMOVED	FAILURE RATE
AMERICAN	9,259	231	80	10%
SCHLUMBERGER	399	8	5	0%
MISCELLANEOUS	917	41	24	7%

**\*AR250 Identified as failed sub-family class and removed from American sampling results**