

---

Garrett P. Lent

glent@postschell.com  
717-612-6032 Direct  
717-731-1985 Direct Fax  
File #: 217477

March 18, 2026

***VIA ELECTRONIC FILING***

Matthew L. Homsher, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street, Second Floor  
Harrisburg, PA 17105

**Re: Letter of Notification of Mid-Atlantic Interstate Transmission, LLC for  
Approval of the Farmers Valley-Ridgway 115 Kilovolt Interconnection Project in  
Sergeant Township, McKean County, Pennsylvania  
Docket No. A-2026-3060524**

---

Dear Secretary Homsher:

Enclosed please find the responses of Mid-Atlantic Interstate Transmission, LLC (“MAIT”) to the Data Requests issued by the Bureau of Technical Utility Services (“TUS”) Set III, on March 5, 2026, in the above-referenced matter.

If you have any questions pertaining to this matter, please do not hesitate to contact me.

Respectfully submitted,



Garrett P. Lent

GPL/tjc  
Attachments

cc: Deb Backer, Bureau of Technical Utility Services (*via email; w/attachments*)  
Jordan Van Order, Bureau of Technical Utility Services (*via email; w/attachments*)

Bureau of Technical Utility Services – Data Requests

Docket Nos. A-2026-3060524

Letter of Notification of Mid-Atlantic Interstate Transmission, LLC for Approval to Construct the Farmers Valley – Ridgeway 115 kV Transmission Line Interconnection Project in McKean County, Pennsylvania

March 18, 2026

**QUESTION A-9**

Reference the Letter of Notification, Paragraph 18. Please explain whether the total length of each segment, above ground and underground, is approximately 320 feet in length. If not, please provide the total length of each segment of the Farmers Valley – Ridgeway 115 kV Transmission Line loop.

**Response:**

Each segment of the transmission line loop is approximately 348 feet. This includes approximately 330 feet of underground conductor from the new inline structures (#150A & #151A) on the existing Farmers Valley-Ridgeway 115 kV Transmission Line to new structures #150 B & #151B, as well as approximately 18 feet of above ground conductor between new structures #150 B & #151B and the 5 Mile Run Substation fenceline.

**BEFORE THE  
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**LETTER OF NOTIFICATION OF** :  
**MID-ATLANTIC INTERSTATE** :  
**TRANSMISSION, LLC FOR** :  
**APPROVAL OF THE FARMERS** :  
**VALLEY-RIDGWAY 115** : **Docket No. A-2026-3060524**  
**KILOVOLT INTERCONNECTION** :  
**PROJECT IN SERGEANT** :  
**TOWNSHIP, MCKEAN COUNTY,** :  
**PENNSYLVANIA** :

**VERIFICATION**

I, Anthony Oberhauser, state that I am a Transmission Specialist for FirstEnergy Service Company; that I am authorized to make this Verification on behalf of Mid-Atlantic Interstate Transmission, LLC; and that the facts set forth in the Letter of Notification are true and correct to the best of my knowledge, information, and belief. I understand that the statements herein are subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).



Date: March 18, 2026

\_\_\_\_\_  
Anthony Oberhauser