

March 23, 2026

Via Electronic Filing

Matthew Homsher, Esquire
Secretary
PA Public Utility Commission
P.O. Box 3265
Harrisburg, PA 17105-3265

Re: Docket No. C-2025-3056062
Jason K. Overholt v. FirstEnergy Pennsylvania Electric Company
2nd Status Report of FE PA (Penelec Rate District)

Dear Secretary Homsher:

Attached for filing is the 2nd Status Report of FirstEnergy Pennsylvania Electric Company (Penelec Rate District) in connection with the above-referenced proceeding.

A copy of the enclosed Status Report has been provided to the Complainant in the manner indicated on the attached Certificate of Service.

If there are any questions, please do not hesitate to contact me.

Very truly yours,

Reger Rizzo & Darnall LLP



Margaret A. Morris

MAM/mam
Enclosures

cc: The Hon. John M. Coogan, PA Public Utility Commission [w/encls.]
Tori Giesler, Esquire, FirstEnergy Service Company [w/encls.]
Jason K. Overholt [w/encls.]

**Re: Docket No. C-2025-3056062
Jason K. Overholt v. FirstEnergy Pennsylvania Electric Company
2nd Status Report of FE PA (Penelec Rate District)**

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing document has been served upon the following person(s), in the manner indicated, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a participant).

Via Electronic Mail

Jason K. Overholt
jloverholt@gmail.com

Dated: March 23, 2026



Margaret A. Morris, Esquire

March 23, 2026

Via Electronic Mail

The Honorable John M. Coogan
jcoogan@pa.gov

**Re: Docket No. C-2025-3056062
Jason K. Overholt v. FirstEnergy Pennsylvania Electric Company
Status Report of FE PA (Penelec Rate District)**

Your Honor:

Pursuant to the *Continuance Order*, dated February 6, 2026, FirstEnergy Pennsylvania Electric Company, Penelec Rate District, (Company) respectfully submits this 2nd Status Update regarding the service provided to Jason K. Overholt (Complainant).

2-Year Outage History

Per the Company's database, the Complainant experienced a sustained outage on March 12, 2026, due to a broken primary neutral caused by a high wind event. The outage lasted 34 minutes and 435 customers were impacted. Crews made the proper switching and repairs to restore customers in a safe and timely manner.

Per the Complainant's smart meter history, the Complainant experienced 3 new momentary interruptions since October 1, 2025. One was on January 26, 2026 due to planned switching. The other two were on March 12, 2026, in relation to the sustained outage event that day.


Work Updates

- Scheduled for Fall 2026, the Company has scheduled the installation of a new SCADA controlled Viper recloser in the Honey Grove Substation.

I spoke to the Complainant today. **The parties respectfully request that the matter be continued until after July 1, 2026, so that the Complainant can be assured that the actions taken by the Company have improved the reliability of the service provided. Thank you for considering the joint request.**

Very truly yours,

Reger Rizzo & Darnall LLP



Margaret A. Morris, Esquire

MAM/mam

cc: Tori Giesler, Esquire, FirstEnergy Service Company
Jason K. Overholt