



**Submit reports to the PA PUC Secretary's Bureau through eFiling at efiling.puc.pa.gov
 Include case: Docket number M-2026-3059557 in the notification
 Also Email To: Safety Division
 Email To The Following Addresses: RA-PC-Pipelinesafety@pa.gov & TCSmith@pa.gov**

Regional Engineering Office

One UGI Center, Wilkes Barre, PA 18711

Description of Proposed Work

To install one new district regulator station PA100 and approximately 260 LF of 6" (LP) and 335 LF of 4" (LP) gas main to replace district regulator stations PA45 and PA46. The work will be performed on private property (UGI Easement), N Main St, and Keating Ave in Port Allegany Borough.

Location of Proposed Work

Port Allegany Borough, McKean County

Type of Facility

Natural Gas District Regulator Station and Distribution Main

Estimated Starting Date

6/1/2026

Design Pressure (MAOP)

150

Estimated Cost

\$835,500.00

Reporting Gas Company for Project

UGI Central

Project Contact Person(s)

Cinti, Christopher



Project Contact Person(s) Address & Phone

511 E Northampton St, Wilkes-Barre, PA 18711; 570-417-6041

Estimated Completion Date

6/26/2026

Notifier's Title (Proposition)

Sr. Manager M&R Engineering Design

Notified By (Proposition)

Wentz, Chester



Notification Date (Proposition)

4/2/2026

Notifier's Title (Actual Completion)

Notified By (Actual Completion)

Notification Date (Actual Completion)

12/31/2001