

NANTMEAL WARWICK SEWER COMPANY, INC.

April 10, 2026

Matthew L. Hornsher, Secretary, PA PUC, 400 N. St., Harrisburg, PA 17120

Re: Docket No. G-205-3053165, Utility Code 230086

TUS Data Request Set 2

Answers:

G-13 & G-14. NWSC is a lagoon treatment system followed by a filtration system, millions of gallons of storage and irrigation pumps to irrigate 250 acres of golf course. Unlike mechanical treatment plants, much of the treatment and disposal relates to storage and irrigation management of treated water; treated to potable water standards. The water is not used as potable water but instead is used to irrigate a golf course surrounded by 8 monitoring wells requiring quarterly sampling for 8 parameters, annual sampling for 7 additional parameters and spray permit renewal every 5 years. There are more services for the water required after treatment than in collection and treatment.

NWSC believes our affiliated interest agreement adequately describes the services we need from our Service Company but will gladly add additional language the PUC considers necessary to protect the customer base we serve.

Should this answer to G-13 and G-14 satisfactorily satisfy this request, G-15 becomes unnecessary.