



Regulation is a maze. We can show you the way!

Whitney E. Snyder
717.703.0807
wesnyder@hmslegal.com

501 Corporate Circle, Suite 302, Harrisburg, PA 17110 Phone: 717.236.1300 Fax: 717.236.4841 www.hmslegal.com

April 17, 2026

By Electronic Filing

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street – Second Floor North
Harrisburg, PA 17120

RE: Pike County Light & Power Company's Request for Exclusion of Major Outage for Reliability Reporting Purposes to Pennsylvania Public Utility Commission; Docket No. _____

Dear Secretary Homsher:

Enclosed for filing is Pike County Light & Power Company's Request for Exclusion of Major Outage for Reliability Reporting Purposes for an outage occurring March 28, 2026.

If you have any questions concerning this filing, please contact me.

Very truly yours,

/s/ Whitney E. Snyder

Whitney E. Snyder (Attorney ID No. 316625)
Counsel for Pike County Light & Power Company

WES/das
Enclosures



Pike Count Light & Power Co.
105 Schneider Ln.
Milford Pa. 18337

Lawrence Gaffney
Electric Manager
570-832-2988 Ext. 361
FAX:(570) 832-2989

April 17, 2026

Honorable Matthew L. Homsher Secretary
Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17105-3265

Re: Request for Exclusion of Major Outage for Reliability Reporting Purposes

Dear Secretary Homsher:

By this letter, Pike County Light & Power Company ("PCL&P") sets forth a 'Request for Exclusion of Major Outage For Reliability Reporting Purposes', in accordance with the Pennsylvania Public Utility Commission ("PAPUC") Order entered May 11, 2004, at M-00991220. This request relates to interruptions to PCL&P customers that occurred on March 28, 2026. This incident meets the 10% customer threshold identified in Pa. Code §57.192, and was the result of a motor vehicle collision.

On March 28, 2026, A motor vehicle collided with a pole compromising its structural integrity. In order to protect the safety of both the public and the restoration crews, a decision was made to de-energize a section of Circuit 116-4-34. As a result, 1,298 customers were interrupted. Since the number of customers affected exceeds the criteria for exclusion, PCL&P respectfully requests that the PAPUC accept this interruption as a Major Event.

Sincerely,

Lawrence Gaffney

Attachment (1)

- (c) Reason for interruption or outage, including weather data where applicable:

During the early morning hours of March 28, 2026, A truck towing a large trailer, carrying a small school bus, struck pole 37102/48230. The pole remained embedded in the truck, creating an unstable condition. The pole sustained severe structural damage, with breaks at both the base and approximately 20 feet above ground near its midpoint, significantly increasing the hazard level of the situation. The structural integrity of the pole was compromised to the point in which any movement could have caused the pole to collapse onto the vehicle or the roadway. In order to protect the safety of the public and the restoration crews, as well as overall system integrity, a decision was made to de-energize a section of Circuit 116-4-34. Weather was not a factor in this outage.

- (d) The number of utility workers and others assigned specifically to the repair work:

There was a total of seven utility workers specifically assigned to the repair work. Staffing included: the Electric Manager, a Senior Designer, one General Foreman, two Foremen, one First Class Journeyman Linemen and an Apprentice Lineman.

- | | |
|--|------------------------|
| (e) The date and time of the first notification of a service interruption: | 3/28/2026
2:00 a.m. |
| (f) The actual time that service was restored to the last affected customer: | 3/28/2026
7:10 a.m. |

CERTIFICATE OF SERVICE

I hereby certify that I have this day served a true copy of the foregoing document upon the parties, listed below, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a party).

BY ELECTRONIC MAIL ONLY

<p>Kelly A. Monaghan, Director Bureau of Audits Pennsylvania Public Utility Commission Commonwealth Keystone Building 400 North Street, 3rd Floor East Harrisburg, PA 17120 kmonaghan@pa.gov</p>	<p>Paul Diskin, Director Bureau of Technical Utility Services Pennsylvania Public Utility Commission Commonwealth Keystone Building 400 North Street, 3rd Floor East Harrisburg, PA 17120 pdiskin@pa.gov</p>
--	--

/s/ Whitney E. Snyder
Whitney E. Snyder

Dated this 17th day of April, 2026.