
Devin Ryan

dryan@postschell.com
717-612-6052 Direct
717-731-1985 Direct Fax
File #: 216478

April 20, 2026

VIA ELECTRONIC FILING

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
P.O. Box 3265
Harrisburg, PA 17105-3265

**Re: Electric Load Forecast Accountability
Docket No. M-2025-3058814**

Dear Secretary Homsher:

Enclosed for filing on behalf of UGI Utilities, Inc. – Electric Division (“UGI Electric” or the “Company”) is the Company’s response to the Bureau of Technical Utility Services’ (“TUS”) Data Request Set 2 served on April 10, 2026.

As set forth in the enclosed filing, a public PDF copy of the Large Load Workbook is included with this response. UGI Electric will be submitting CONFIDENTIAL Excel and PDF copies of the Large Load Workbook to the Commission via the Commission’s CONFIDENTIAL filing process.

Copies will be provided as indicated on the Certificate of Service.

Respectfully Submitted,



Devin Ryan

DR/tjc
Attachment

cc: Clinton McKinley, TUS (*via email w/attachment*)
Dan Searforce, TUS (*via email w/attachment*)

Matthew L. Homsher, Secretary
April 20, 2026
Page 2

John Van Zant, TUS (*via email w/attachment*)
Kriss Brown, LAW (*via email w/attachment*)
Certificate of Service

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of this filing has been served upon the following persons, in the manner indicated, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a participant).


VIA E-MAIL

Allison Kaster, Esquire
Bureau of Investigation & Enforcement
Commonwealth Keystone Building
400 North Street, 2nd Floor West
PO Box 3265
Harrisburg, PA 17105-3265
E-mail: akaster@pa.gov

NazAarah Sabree
Office of Small Business Advocate
555 Walnut Street
Forum Place, 1st Floor
Harrisburg, PA 17101
E-mail: ra-sba@pa.gov

Darryl A. Lawrence, Esquire
Office of Consumer Advocate
555 Walnut Street
Forum Place, 5th Floor
Harrisburg, PA 17101-1923
E-mail: dlawrence@paoca.org

Dated: April 20, 2026



Devin T. Ryan

UGI Utilities, Inc. – Electric Division
Response to TUS Data Request Set 2

Docket No. M-2025-3058814
Served on April 10, 2026

M-4:

In response to M-3 of the Commission’s Data Request Set 1, UGI Electric indicated that it does not have any executed contracts and/or agreements currently in effect with any Large Load Customer. However, M-3 requested the completion of all worksheets in the Large Load Workbook provided at <https://www.puc.pa.gov/pcdocs/1906205.xlsx>. Please provide a complete response to M-3. If portions of UGI Electric’s response are deemed confidential, please provide a confidential and a redacted public version, pursuant to Commission regulations at 52 Pa. Code § 1.32(b)(4).

The worksheets in order are:

- i. 20-year Demand Forecast
- ii. 20-year Peak Load Forecast
- iii. Large Load Customer Listing
- iv. Load Factors
- v. Large Load Adjustment Forecast Detail
- vi. Large Load Customer Questions
- vii. Retirements

Respondent:

Vince DeGiusto, Jr.
Senior Director – Electric Division

Response:

Enclosed as **Attachment A** is a public PDF copy of the Large Load Workbook in which the CONFIDENTIAL information has been redacted. CONFIDENTIAL Excel and PDF copies of the Large Load Workbook are being filed with the Commission using the CONFIDENTIAL filing process.

M-2025-3058814

UGI Utilities, Inc. - Electric Division

Vince Degiusto

570-830-1289

VDeGiustoJr@ugi.com

Instructions:

Please complete this workbook in its entirety and file a live electronic copy with the Secretary of the Commission at the address listed below or using the Commission's Share Point File system.

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

If your filing contains confidential material, you are required to either file by overnight delivery or submit to the Secretary's Share Point File system to ensure the timely filing of your submission. Filers should contact the Secretary's Bureau in advance to gain access to the Share Point File system. Make sure to reference the Docket Number listed above when filing your response.

Definitions:

Large Load Customer: A Large Load Customer is defined as a customer with maximum contract capacity of 50 MW or above individually or multiple closely located customers with maximum contract capacity of 100 MW or greater in the aggregate.

M-2025-3058814

UGI Utilities, Inc. - Electric Division
Vince Degiusto
570-830-1289
VDeGiustoJr@ugi.com

Please provide a 20-year calculated demand forecast that provides the following breakdown of system demand.

Year	Forecast Energy Demand (MWh)					TOTAL	Forecast Impacts from Select Sectors (MWh)		
	Residential	Commercial	Industrial	Other	Resale		Data Centers*	Electrification Impacts, e.g., EV, Solar, Heating, etc.	Industrial/Manufacturing Growth
2026	554,878	320,554	98,493	4,773	126	978,824			
2027	556,408	529,312	98,493	4,773	126				
2028									
2029									
2030									
2031									
2032									
2033									
2034									
2035									
2036									
2037									
2038									
2039									
2040									
2041									
2042									
2043									
2044									
2045									
2046									

[Redacted]

M-2025-3058814

UGI Utilities, Inc. - Electric
Vince Degiusto
570-830-1289
VDeGiustoJr@ugi.com

Please provide a 20-year calculated system Peak Load Forecast as follows:

Year	Forecast Peak Load (MW)				TOTAL	Forecast Peak Load Impacts from Select Sectors (MW)		
	Summer	Winter	Annual	Annual Load Factor		Data Centers*	Electrification Impacts, e.g., EV, Solar, Heating, etc.	Industrial/Manufacturing Growth
2026	202	204	204	0.55	611			
2027								
2028								
2029								
2030								
2031								
2032								
2033								
2034								
2035								
2036								
2037								
2038								
2039								
2040								
2041								
2042								
2043								
2044								
2045								
2046								

█

M-2025-3058814

UGI Utilities, Inc. - Electric Division
Vince Degiusto
570-830-1289
VDeGiustoJr@ugi.com

Identify any load factors used to calculate demand for certain load types.

Load Type	Load Factor
Commercial Office	0.5
Data Center	0.95
EV	0.5
Industrial	0.8
Medical Center	0.7
Refrigerated Storage	0.85
Stadium	0.3
Water/Wastewater Treatment	0.8
Other	0.6
Residential	0.4

Add rows as necessary

Total Load Growth through 2046

VERIFICATION

I, Vince DeGiusto, Jr., Senior Director – Electric Division of UGI Utilities, Inc., hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

Date: April 20, 2026

Signed by:

2FCECE4C94664B0...

Vince DeGiusto, Jr.