

M-2026-3059557

PUC Notification – Major Construction Report

PECO Gas Projects Exceeding \$300,000

Notification Date:4/21/2026

PA §59.38	Information Requested by PUC	Data Provided by PECO
1	Description of Proposed Work (e.g., replace 700' of 4" cast iron, new regulator station, etc.)	Install 1790 of plastic Renew 27 services Retire 1192ft of cast iron Retire 825ft of steel
	City/Borough/Township and County	West Chester boro., Chester County
	Extents of Project (e.g., Main St. from 4th to 7th)	E Washington St, N Adams st, Chestnut st
2	Type of Facility (if other, please describe)	<input checked="" type="checkbox"/> Distribution Main/Services <input type="checkbox"/> Transmission Main <input type="checkbox"/> Regulator/Gate Station <input type="checkbox"/> Other: Click or tap here to enter text.
3	Estimated Starting Date	9/15/2026
4	Estimated Completion Date	12/3/2026
5	Design Pressure	HP
6	Estimated Cost	\$752,706
7	Reporting Company (name and address)	PECO, an Exelon Company 2301 Market St Philadelphia, PA 19103
8	Project Contact (name, address and phone number)	Dwight Lasure 300 Front St—Building #2 Conshohocken, PA 19428-2723 Phone: 267-533-1420
9	Actual Completion Date (to be sent after project complete)	