



Operations Center
2839 New Beaver Avenue
Pittsburgh PA 15233

April 30, 2026

VIA ELECTRONIC FILING

Secretary Matthew Homsher
Pennsylvania Public Utility Commission
Secretary's Bureau
Commonwealth Keystone Building
400 North Street
Harrisburg PA 17120

Re: Duquesne Light Company – Request for Exclusion of Major Outage for Reliability Reporting Purposes

Secretary Matthew Homsher:

Enclosed please find a Request for Exclusion of Major Outage for Reliability Reporting Purposes for the storm event that occurred in Duquesne Light Company's (Duquesne or the Company) service territory on Friday, March 13, 2026, pursuant to the requirements established by Commission Order at Docket No. M-00991220.

Should you require additional information, please contact me at (412) 393-8324.

Sincerely,

A handwritten signature in blue ink that reads "Wesley Terek". The signature is written in a cursive, flowing style.

Wesley Terek, P.E.
General Manager, System Planning & Protection

cc: Dan Searfoorce
Derek Ruhl
John Van Zant

REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR
RELIABILITY REPORTING PURPOSES TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
P O BOX 3265
HARRISBURG, PA 17105-3265

An original of this request is to be either electronically filed (eFiled) with the Commission or filed in paper form with the Secretary's Bureau.

Information Required:

1. Reporting Utility: Duquesne Light Company
Address: 2839 New Beaver Avenue
Pittsburgh PA 15233

2. Name and title of person making report:
Wesley Terek General Manager, System Planning & Protection
(Name) **(Title)**

3. Telephone number: 412-393-8324
(Telephone Number)

4. Interruption or Outage:
(a) Number of customers affected:
Total number of customers in service territory:

194,908 customers, constituting approximately 32% of the 617,922 customers in
Duquesne Light's service territory.

- (b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

Allegheny County had a total of 1,300 troubled locations and 628 outages while Beaver County had a total of 253 troubled locations and 225 outages for a combined total of 1,553 troubled locations and 853 outages in Duquesne Light’s service territory.

Please see the listing of troubled locations by county/municipality in section (f) of this report.

- (c) Reason for interruption or outage, including weather data where applicable.

At approximately 1400 on Friday, March 13, 2026, Duquesne Light’s service territory was affected by severely high winds that persisted into Saturday, March 14, 2026. This weather caused downed power lines, fallen trees, and damage to our poles and equipment. The National Weather Service (NWS) reported that the highest wind speed during this storm was 45 mph and the highest wind gust was 66 mph.

Additional weather information is included at the end of this report.

- (d) The number of utility workers and others assigned specifically to the repair work:


Utility / Company	# of Workers	General Function
Duquesne Light	243	Lineworkers
Duquesne Light	55	Troubleshooters
Duquesne Light	53	Substations
Duquesne Light	75	Underground
DLC	11	Vegetation Management / Tree Crews
Cut Above	42	
Nelson	56	
Penn Line	52	
Wright	61	
Henkels & McCoy	42	Lineworker Contractors
JW Didado	8	
PAR	15	
Sargent	58	
WA Chester	22	
GMB	180	Mutual Assistance
Northline Compass	140	
Vision	60	

(i) The date and time of the first information of a service interruption:

Friday, March 13, 2026 at 1356 hours.

(e) The actual time that service was restored to the last affected customer:

Friday, March 20, 2026 at 1530 hours.



Storm restoration updates were provided to our customers and the media through our Duquesne Light website, Facebook and on X. Weather information and photos are attached.

Please also see Duquesne's Electric Utility Report of Outage, dated April 24, 2026, for more information regarding this outage event.

(f) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

Allegheny County Municipalities	Trouble Cases
Allison Park	58
Braddock	20
Bridgeville	7
Carnegie	24
Cheswick	11
Clairton	6
Coraopolis	25
Dravosburg	1
Duquesne	1
East Pittsburgh	2
Elizabeth	1
Gibsonia	50
Glassport	1
Glenshaw	34
Homestead	7
Mc Kees Rocks	10
Mckeesport	18
Monroeville	46
New Kensington	10
North Versailles	12
Oakdale	12
Oakmont	4
Pittsburgh	722
Trafford	1
Turtle Creek	13
Verona	43
West Mifflin	21
Wexford	2
Wilmerding	8
Grand Total	1170

Beaver County Municipalities	Trouble Cases
Aliquippa	72
Ambridge	17
Baden	26
Beaver	14
Beaver Falls	17
Clinton	15
Conway	2
Coraopolis	25
Crescent	16
Darlington	3
Freedom	11
Georgetown	17
Hookstown	18
Imperial	10
Industry	4
McKees Rocks	1
Midland	3
Monaca	14
New Brighton	24
Oakdale	1
Rochester	2
Sewickley	50
Shippingport	2
South Heights	1
Grand Total	365

Figures and Other Attachments

NWS Notifications:

On Thursday, March 12, 2026 at 0352 hours:

- The National Weather Service issued a Wind Advisory for Friday, March 13, 2026.

On Friday, March 13 at 0300 hours:

- The National Weather Service emailed an updated outlook for a high wind event on Friday, March 13, 2026.

On Friday, March 13 at 1340 hours:

- The National Weather Service emailed an updated outlook for a high wind event on Friday, March 13, 2026.

On Friday, March 13 at 1648 hours:

- The National Weather Service upgraded the Wind Advisory to a High Wind Warning for Friday, March 13, 2026.

Storm Photos:







