



Direct Dial: 267-533-1830
khadijah.scott@exeloncorp.com

September 16, 2025

VIA E-MAIL

Honorable Alphonso Arnold, ALJ
Pennsylvania Public Utility Commission
801 Market Street, 4th Floor, STE 4063
Philadelphia, PA 19107

RE: Dayna Sobanko v. PECO Energy Company
Docket No. C-2025-3054654
Date of Hearing: September 22, 2025 @ 10:00 a.m.

Dear Judge Arnold:

Enclosed please find a copy of PECO Energy Company's Exhibits 1 through 2, which it intends to use in the above referenced hearing. By copy of this letter, I am sending a copy of same to the Complainant.

Please call my direct dial number if you have any questions regarding this case.

Respectfully submitted,

A handwritten signature in blue ink that reads "Khadijah Scott".

Khadijah Scott

KS/ld
Enclosure

Cc: Dayna Sobanko (via email)

EXHIBIT 1

PECO standard/NEC clearances.

13kv facilities 7'6" horizontally to building

Field verification closest 13kv is about 9.5' from the building.

TABLE

CLEARANCE OF	34 KV			13 KV				4 KV *				
	OPEN & SPACER		C1	OPEN		SPACER	C1	OPEN		SPACER	C1	C3
	O	S		BARE	COVD			BARE	COVD			
	FEET			FEET				FEET				
BUILDINGS:												
HORIZONTAL												
TO WALLS, PROJECTIONS & GUARDED PARTS	9'-0"	9'-0"	4'-6"	7'-6"	7'-6"	7'-6"	4'-6"	7'-6"	7'-6"	7'-6"	4'-6"	5'-6"
TO GUARDED WINDOWS (NOTE 4)	9'-0"	9'-0"	4'-6"	7'-6"	7'-6"	7'-6"	4'-6"	7'-6"	7'-6"	7'-6"	4'-6"	5'-6"
TO BALCONIES AND AREAS READILY ACCESSIBLE TO PEDESTRIANS (NOTE 3)	9'-0"	9'-0"	4'-6"	7'-6"	7'-6"	7'-6"	4'-6"	7'-6"	7'-6"	7'-6"	4'-6"	5'-6"
VERTICAL												
OVER OR UNDER ROOFS OR PROJECTIONS NOT READILY ACCESSIBLE TO PEDESTRIANS (NOTE 3)	16'-6"	13'-6"	4'-0"	16'-6"	16'-6"	13'-6"	4'-0"	16'-6"	16'-6"	13'-6"	4'-0"	11'-6"
OVER OR UNDER BALCONIES AND ROOFS READILY ACCESSIBLE TO PEDESTRIANS (NOTE 3)	17'-6"	16'-0"	11'-6"	17'-6"	17'-6"	15'-0"	11'-6"	17'-6"	17'-6"	15'-0"	11'-6"	12'-6"
OVER ROOFS ACCESSIBLE TO VEHICLES OVER 8' HIGH	23'-6"	21'-0"	16'-6"	22'-6"	22'-6"	20'-0"	18'-6"	22'-6"	22'-6"	20'-0"	18'-6"	17'-6"
OVER ROOFS ONLY ACCESSIBLE TO VEHICLES LESS THAN 8' HIGH	23'-6"	21'-0"	11'-6"	22'-6"	22'-6"	20'-0"	11'-6"	22'-6"	22'-6"	20'-0"	11'-6"	12'-6"
SIGNS, CHIMNEYS, BILLBOARDS, RADIO & TELEVISION ANTENNAS, TANKS & OTHER INSTALLATIONS NOT CLASSIFIED AS BUILDINGS OR BRIDGES												
HORIZONTAL	9'-0"	9'-0"	3'-0"	7'-6"	7'-6"	7'-6"	3'-0"	7'-6"	7'-6"	7'-6"	3'-0"	5'-6"
VERTICAL												
(1) OVER OR UNDER CATWALKS AND OTHER SURFACES UPON WHICH PERSONAL WALK	17'-6"	16'-0"	11'-6"	17'-6"	17'-6"	15'-0"	11'-6"	17'-6"	17'-6"	15'-0"	11'-6"	12'-6"
(2) OVER OR UNDER OTHER PORTIONS OF SUCH INSTALLATIONS	12'-0"	9'-0"	4'-0"	12'-0"	12'-0"	9'-0"	4'-0"	12'-0"	12'-0"	9'-0"	4'-0"	7'-0"

(NESC 2017 RULE 234A & 234C)

EXHIBIT 2

Tariff Electric Pa. P.U.C. No. 8

PECO Energy Company Original Page No. 20

RULES AND REGULATIONS (continued)

10.7 POLE REMOVAL OR RELOCATION REQUESTED BY RESIDENTIAL PROPERTY OWNERS.

The cost for removal or relocation of distribution line poles and their associated attachments made pursuant to the request of a residential property owner who is not entitled to receive condemnation damages to cover the cost of such work shall be borne by the property owner and shall be limited to contractor, direct labor, and direct material costs incurred less maintenance expenses avoided as a result of the pole removal or relocation. The calculation of such cost for removal or relocation shall be in accordance with the Public Utility Commission Regulations - Title 52, Section 57.27. Issued.

Issued December 18, 2024

Effective January 1, 2025