



"Clean Water Today for a Better Tomorrow"

P.O. BOX 1488 • SKIPPACK, PA 19474 • P (610) 584-3593 • F (610) 584-0596 • alliedutilityservicesinc@gmail.com

30 March 2024

C-2025-3057638

Rodney & Danielle Day
5070 Cassidy Drive
Schnecksville, PA 18078

emailed to: rday574@gmail.com

Re: Sewer Service Line Repair

Dear Mr. & Mrs. Day:

The collapse of your building sewer was due to improper installation by the builder. (2) 90-degree elbows were used when your gravity sewer line was first installed. This is never allowed. Any reputable contractor knows this. In addition, the cleanout cap was not glued & the top was buried. This allowed the cleanout riser pipe to fill with dirt. You now have (2) 4" cleanouts at each change of pipe direction as required. The top of these pipes must always remain a minimum of 6" above the lawn or any landscaping cover for continuous accessibility.

The builder of your home violated AUSI's PUC regulations when they initially connected the building sewer line from your home to our service line without the required AUSI inspection & approval. AUSI also did not inspect your adjacent 3 neighbors. This is the second such failure in these 4 homes. AUSI did inspect all other homes in the development. We are not aware of any similar failures in the development.

This letter shall serve as AUSI approval for the repair of your customer service line by Andreas Plumbing & HVAC on 3/29/24 in accordance with our PUC requirements governing the sewer service provided to you. The depth of the excavation and prior rain in the open trench resulted in dangerous conditions at the lateral point of connection. Andreas did an excellent job overcoming the site challenges to finally complete this extremely difficult repair that was started by others.

Respectfully,

ALLIED UTILITY SERVICES, INC.

James Wilson

James Wilson
President

Cc: Jeff Mouer, NWT; jmouer@northwhitehall.org
Steve Gitch, P.E., NWT; sgitch@kceinc.com
Randy Cope, NWT; rcope@northwhitehall.org
Charley Myers, P.E., BIA; cmyers@barrissett.com
Shawn Althouse, Andreas; shawn@andreas-plumbing.com