

---

Megan E. Rulli

mrulli@postschell.com  
717-612-6012 Direct  
717-731-1985 Direct Fax  
File #: 215703

May 18, 2026

***VIA ELECTRONIC FILING***

Matthew L. Homsher, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street, 2nd Floor North  
P.O. Box 3265  
Harrisburg, PA 17105-3265

**Re: Letter Of Notification Of PPL Electric Utilities Corporation, Filed Pursuant To 52 Pa. Code Chapter 57 Subchapter G, For Approval To Build Approximately 0.25 Miles Of New Double Circuit 138 kV Transmission Tap Lines To Connect The Existing Akron – Prince #1 & #2 138 kV Transmission Lines To The New Pitney 138 kV Switchyard And To Build Two Double Circuit 0.1-Mile-Long 138 kV Transmission Lines From The Pitney 138 kV Switchyard To A New Customer-Owned 138-34 kV Substation Located In East Lampeter Township, Lancaster County, Pennsylvania  
Docket No. A-2026-3062201**

Dear Secretary Homsher:

Enclosed, on behalf of PPL Electric Utilities Corporation (“PPL Electric”), is information being supplied to the Pennsylvania Public Utility Commission’s (“Commission”) Bureau of Technical Utility Services (“TUS”) in response to Data Requests issued on May 8, 2026, in the above-referenced proceeding.

Respectfully submitted,



Megan E. Rulli

MER/sll  
Attachment

cc: Jordan Van Order, Bureau of Technical Utility Services (*via email; w/attachment*)

**PPL Electric Utilities Corporation**  
**Response to the Set I Data Requests of the**  
**Bureau of Technical Utility Services (TUS)**  
**Dated May 8, 2026**  
**Docket No. A-2026-3062201**

A-1                      Reference the Letter of Notification, Paragraph 36. Please state the approximate width of the right-of-way.

PPL Electric              The approximate width of the transmission line right-of-way is  
Response                      100 feet.

**PPL Electric Utilities Corporation**  
**Response to the Set I Data Requests of the**  
**Bureau of Technical Utility Services (TUS)**  
**Dated May 8, 2026**  
**Docket No. A-2026-3062201**


A-2                      Reference the Letter of Notification, Attachment 1, Section 4.2.  
Please state the current load of the customer.

PPL Electric              The site is currently not operational and the load is 0 megawatts  
Response                  (“MW”). Prior to retirement of the facilities, the customer load  
was approximately 10 MW.

## VERIFICATION

I, JOSEPH B. LOOKUP, being the Vice President – Transmission & Distribution Planning and Asset Management at PPL Services Corporation, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief and that I expect PPL Electric Utilities Corporation to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 relating to unsworn falsification to authorities.

Date: May 18, 2026

  
\_\_\_\_\_  
Joseph B. Lookup