
Hayley E. Wilburn

hwilburn@postschell.com
412-506-6362 Direct
412-227-9065 Direct Fax
File #: 218966

May 18, 2026

VIA ELECTRONIC FILING


Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, Second Floor
Harrisburg, PA 17105

**Re: Letter Of Notification Of PPL Electric Utilities Corporation, Filed Pursuant To 52 Pa. Code Chapter 57 Subchapter G, For Approval To Build Approximately 0.5 miles of New Double-Circuit 138/69 kV Transmission Taps That Are Needed to Connect the Existing AT&T R&D 138/69 kV Tap Transmission Lines to the New TEK Park 138/69-13 kV Substation and To Construct Approximately 0.75 miles of New Double Circuit 138/69 kV Lines from the Breinigsville 500-133-69 kV Substation to the new TEK Park 138/69 kV Tap Lines in Upper Macungie Township, Lehigh County, Pennsylvania
Docket No. A-2026-3062204**

Dear Secretary Homsher:

Enclosed, on behalf of PPL Electric Utilities Corporation (“PPL Electric”), is information being supplied to the Pennsylvania Public Utility Commission’s (“Commission”) Bureau of Technical Utility Services (“TUS”) in response to Data Requests issued on May 8, 2026, in the above-referenced proceeding.

Respectfully submitted,



Hayley E. Wilburn

HW/bfc
Enclosures

Matthew L. Homsher, Secretary

May 18, 2026

Page 2

cc: Deb Backer, Bureau of Technical Utility Services (*via electronic service*)
Jordan Van Order, Bureau of Technical Utility Services (*via electronic service*)
Certificate of Service

PPL Electric Utilities Corporation
Response to the Set I Data Requests of the
Bureau of Technical Utility Services (TUS)
Dated May 8, 2026
Docket No. A-2026-3062204

A-1 Reference the Letter of Notification, Paragraph 9. Please provide the date(s) of the PJM RTEP meeting(s) the subject project was presented at.

PPL Electric PJM RTEP Need Presentation – July 18, 2024
Response PJM RTEP Solution Presentation – September 19, 2024
 PJM RTEP Local Plan Submission – March 18, 2025

WITNESS: Joseph B. Lookup

PPL Electric Utilities Corporation
Response to the Set I Data Requests of the
Bureau of Technical Utility Services (TUS)
Dated May 8, 2026
Docket No. A-2026-3062201


A-2 Reference the Letter of Notification, Attachment 3, page 1.
Please state the approximate width of the right-of-way.

PPL Electric The approximate width of the right-of-way is 100 feet.
Response

VERIFICATION

I, JOSEPH B. LOOKUP, being the Vice President – Transmission & Distribution Planning and Asset Management at PPL Services Corporation, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief and that I expect PPL Electric Utilities Corporation to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 relating to unsworn falsification to authorities.

Date: May 18, 2026



Joseph B. Lookup