
Megan E. Rulli

mrulli@postschell.com
717-612-6012 Direct
717-731-1985 Direct Fax
File #: 218801

May 18, 2026

VIA ELECTRONIC FILING

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
P.O. Box 3265
Harrisburg, PA 17105-3265

**Re: Letter of Notification of Mid-Atlantic Interstate Transmission, LLC for Approval of the Mehoopany-North Meshoppen No. 1 And No. 2 115 Kilovolt Transmission Lines Rebuild Project In Auburn Township, Susquehanna County And Washington Township, Wyoming County, Pennsylvania
Docket No. A-2026-3062049**

Dear Secretary Homsher:

Enclosed, on behalf of Mid-Atlantic Interstate Transmission, LLC (“MAIT”), is information being supplied to the Pennsylvania Public Utility Commission’s (“Commission”) Bureau of Technical Utility Services (“TUS”) in response to Data Requests issued on May 6, 2026, in the above-referenced proceeding.

Respectfully submitted,



Megan E. Rulli

MER/sll
Attachment

cc: Jordan Van Order, Bureau of Technical Utility Services (*via email; w/attachment*)

Letter of Notification Filing of Mid-Atlantic Interstate Transmission, LLC Requesting Approval of the Mehoopany-North Meshoppen 115 Kilovolt Transmission Lines Rebuild Project in Auburn Township, Susquehanna County and Washington Township, Wyoming County, Pennsylvania

May 18, 2026

QUESTION A-1

Reference the Letter of Notification, Paragraph 13. Please explain why the NERC, or other regulatory standard, violation, is now an issue where it wasn't previously.

Response:

The reliability criteria violations identified in Paragraph 13 of the Letter of Notification were not present in earlier planning assessments and have emerged due to changes reflected in the most recent PJM RTEP power flow models. PJM planning models have been updated to reflect evolving system conditions, including changes in generation dispatch, system topology, load levels, and operating assumptions. These cumulative changes have altered power flows on the transmission system such that the violations as described in the Letter of Notification now exist.

Letter of Notification Filing of Mid-Atlantic Interstate Transmission, LLC Requesting Approval of the Mehoopany-North Meshoppen 115 Kilovolt Transmission Lines Rebuild Project in Auburn Township, Susquehanna County and Washington Township, Wyoming County, Pennsylvania

May 18, 2026

QUESTION A-2

Reference the Letter of Notification, Paragraph 13. Please explain whether load growth in the area has led to any change in circumstances as it relates to the need for the proposed project. If so, quantify these load growth impacts.

Response:

Load growth in the area has not contributed to the need for the subject project.

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

LETTER OF NOTIFICATION :
OF MID- ATLANTIC :
INTERSTATE :
TRANSMISSION, LLC FOR : **Docket No. A-2026-3062049**
APPROVAL TO REBUILD THE :
EXISTING SINGLE-CIRCUIT :
MEHOOPANY-NORTH :
MESHOPPEN 115 :
KILOVOLT TRANSMISSION LINES :
REBUILD PROJECT IN AUBURN :
TOWNSHIP, SUSQUEHANNA :
COUNTY AND WASHINGTON :
TOWNSHIP, WYOMING COUNTY, :
PENNSYLVANIA :

VERIFICATION

I, Lisa DeFlumeri, state that I am a Transmission Specialist II for FirstEnergy Service Company; that I am authorized to make this Verification on behalf of Mid-Atlantic Interstate Transmission, LLC (“MAIT”); and that the facts set forth herein are true and correct to the best of my knowledge, information and belief. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 (relating to unsworn falsification to authorities).

Date: May 18, 2026



Lisa DeFlumeri