



COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA PUBLIC UTILITY COMMISSION
400 NORTH STREET, HARRISBURG, PA 17120

IN REPLY PLEASE
REFER TO OUR FILE

May 20, 2026

Docket No.: M-2026-3062186
Utility Code: 1126015

ANGELINA UMSTEAD, ESQUIRE
FIRSTENERGY PENNSYLVANIA ELECTRIC COMPANY
341 WHITE POND DRIVE
Akron, OH 44320
aumstead@firstenergycorp.com

RE: FirstEnergy Pennsylvania Electric Company Request for Exclusion of Major Outage for Reliability Reporting Purposes at Docket No. M-2026-3062186

Dear Attorney Umstead:

On May 1, 2026, on behalf of its Penn Power Rate District, FirstEnergy Pennsylvania Electric Company (FE PA) filed a request for exclusion of major outage (Exclusion Request) for reliability reporting purposes in accordance with the requirements of the Pennsylvania Public Utility Commission's (Commission's) Order entered May 11, 2004, at M-00991220.

FE PA stated that the Exclusion Request relates to service interruptions resulting from an intense and widespread windstorm that began on March 13, 2026, and a second wave of strong storms with heavy precipitation and gusty winds that moved through FE PA's service territory between 11:30 hours and 23:30 hours on March 16, 2026. FE PA reported that maximum winds between 55-65 miles per hour were observed throughout the FE PA footprint. Rainfall amounts were generally 0.5-1 inches with some localized areas reporting 1.5-2 inches. FE PA indicated that the Zelienople region was the hardest hit area. Approximately 73.5% of the total outages that occurred were tree-related and 8.9% were wind-related line and equipment damage. In total, approximately 17%, or 30,226 customers out of approximately 175,673 customers, of FE PA's Penn Power Rate District were affected. FE PA noted that 542 utility workers and others specifically assigned to repair work were dispatched. FE PA stated that the first customer service interruption occurred at approximately 14:34 hours on March 13, 2026, and that service was restored to the last affected customer at 03:20 hours on March 18, 2026. The incident resulted in a total of 29,245,410 Customer-Minutes-Interrupted.

Upon review of the company's filing, it appears that the service interruptions described by FE PA qualify as a major event, as defined in 52 Pa. Code § 57.192(i)(A). Therefore, the request for exclusion of service interruptions for reporting purposes is hereby approved. However, the Commission's approval is contingent upon the possibility that subsequent audits, reviews, and inquiry, in any Commission proceeding, may be conducted, pursuant to 52 Pa. Code §57.197 (relating to Reliability investigations and enforcement).

In addition, this approval will apply only to the matter and parties specifically and clearly defined under this instant filing.

If you are dissatisfied with the resolution of this matter, you may, as set forth in 52 Pa. Code §5.44, file a petition with the Commission within 10 days of the date of this letter. If you have any questions on this matter, please contact Clinton McKinley, Bureau of Technical Utility Services, at cmckinley@pa.gov, or (717) 783-6161.

Sincerely,

A handwritten signature in black ink that reads "Matthew L. Homsher". The signature is written in a cursive style with a large, stylized initial "M".

Matthew L. Homsher
Secretary

cc: Dan Searfoorce, TUS
John Van Zant, TUS
Chris Yother, AUD
Kathleen Aunkst, SEC
Brent Killian, BIE