

# Morgan Lewis

**Kenneth M. Kulak**

Partner

+1.215.963.5384

ken.kulak@morganlewis.com

May 27, 2026

## VIA ELECTRONIC FILING

Matthew L. Homsher, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street, 2<sup>nd</sup> Floor North  
Harrisburg, PA 17120

**Re: Letter of Notification of PECO Energy Company Filed Pursuant to 52 Pa. Code §§ 57.71 *et seq.* for Approval of the Siting and Construction of the 220-84 Line, 220-85 Line, and 220-97 Line Located in Marcus Hook Borough and Lower Chichester Township, Delaware County, Pennsylvania  
Docket No. A-2026-3060477**

Dear Secretary Homsher:

Enclosed for filing in the above-captioned proceeding is PECO Energy Company's Response to the Data Request of the Bureau of Technical Utility Services, Question No. A-6.

As indicated on the enclosed Certificate of Service, copies have been served upon all parties of record.

If you have any questions, please call me directly at 215.963.5384.

Very truly yours,



KMK/ap

Enclosure

c: Per Certificate of Service (w/encls.)

**Morgan, Lewis & Bockius LLP**

2222 Market Street  
Philadelphia, PA 19103  
United States

**T** +1.215.963.5000  
**F** +1.215.963.5001

**BEFORE THE  
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Letter of Notification of PECO Energy :  
Company Filed Pursuant to 52 Pa. Code §§ :  
57.71 et seq. for Approval of the Siting and :  
Construction of 220-84 Line, 220-85 Line, :           Docket No. A-2026-3060477  
and 220-97 Line Located in Marcus Hook :  
Borough and Lower Chichester Township, :  
Delaware County, Pennsylvania :**

---

**RESPONSE OF PECO ENERGY COMPANY  
TO DATA REQUEST OF THE BUREAU OF TECHNICAL UTILITY SERVICES**

---

**TUS-A-6:**

Reference the Letter of Notification, Attachment 2, Item 23. Please provide the approximate cost of the second alternate solution.

**RESPONSE:**

The second alternate solution PECO referenced in the Letter of Notification, Attachment 2, Item 23, would require PECO to install two new underground transmission lines extending approximately one mile from the Linwood Substation to the Pennsylvania/Delaware state line, at which point the lines would transition overhead at new terminal yards that PECO would install. The existing 220-84 Line and 220-85 Line would connect to new terminal structures in the new terminal yards and be fed from the Edgemoor Substation and Claymont Substation, respectively. PECO estimates that the cost of this alternative line would be approximately \$36 million. PECO notes that the proposed Project is the most practicable solution to increase the reliability of the Linwood Substation, and given the number of potentially impacted landowners and the technical complexity of the potential alternative, PECO did not perform a formal evaluation of this alternate project.


**BEFORE THE  
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Letter of Notification of PECO Energy :  
Company Filed Pursuant to 52 Pa. Code §§ :  
57.71 et seq. for Approval of the Siting and :                   Docket No. A-2026-3060477  
Construction of the 220-84 Line, 220-85 Line, :  
and 220-97 Line Located in Marcus Hook :  
Borough and Lower Chichester Township, :  
Delaware County, Pennsylvania :**

**VERIFICATION**

I, Drew T. Davis, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

DATE: May 27, 2026



Drew T. Davis  
Vice President, Transmission and Substation

**BEFORE THE  
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Letter of Notification of PECO Energy :  
Company Filed Pursuant to 52 Pa. Code §§ :  
57.71 et seq. for Approval of the Siting and :  
Construction of the 220-84 Line, 220-85 Line, :           Docket No. A-2026-3060477  
and 220-97 Line Located in Marcus Hook :  
Borough and Lower Chichester Township, :  
Delaware County, Pennsylvania :**

**CERTIFICATE OF SERVICE**

I hereby certify and affirm that I have this day served a copy of the **Response of PECO Energy Company to Data Request of the Bureau of Technical Utility Services** on the following persons in the manner specified in accordance with the requirements of 52 Pa. Code § 1.54:

**VIA ELECTRONIC MAIL**


Office of Consumer Advocate  
555 Walnut Street  
Forum Place – 5th Floor  
Harrisburg, PA 17101-1921  
[ra-oca@paoca.org](mailto:ra-oca@paoca.org)

Allison C. Kaster  
PA Public Utility Commission  
Bureau of Investigation and Enforcement  
Commonwealth Keystone Building  
400 North Street, 2nd Floor West  
Harrisburg, PA 17120  
[akaster@pa.gov](mailto:akaster@pa.gov)

NazAarah Sabree  
Small Business Advocate  
Office of Small Business Advocate  
555 Walnut Street  
Forum Place - 1st Floor  
Harrisburg, PA 17101  
[ra-sba@pa.gov](mailto:ra-sba@pa.gov)

Jordan Van Order  
PA Public Utility Commission  
Bureau of Technical Utility Services  
Commonwealth Keystone Building  
400 North Street, 2nd Floor West  
Harrisburg, PA 17120  
[jvanorder@pa.gov](mailto:jvanorder@pa.gov)

Dated: May 27, 2026

  
Kenneth M. Kulak  
Morgan Lewis & Bockius LLP  
2222 Market Street  
Philadelphia, PA 19103-2921  
(215) 963-5384  
[ken.kulak@morganlewis.com](mailto:ken.kulak@morganlewis.com)