



Operations Center
2839 New Beaver Avenue
Pittsburgh PA 15233

June 3, 2026

VIA ELECTRONIC FILING

Secretary Matthew Homsher
Pennsylvania Public Utility Commission
Secretary's Bureau
Commonwealth Keystone Building
400 North Street
Harrisburg PA 17120

Re: Response to Pennsylvania Public Utility Commission Technical Utility Services (TUS) Data Request - DLC Request for Exclusion of Major Outage for Reliability Reporting Purposes at Docket No. M-2026-3062162

Secretary Matthew Homsher:

Enclosed is Duquesne Light Company's response to the Commission's May 20, 2026 data request to assist with its review of the Request to the Pennsylvania Public Utility Commission for Exclusion of Major Outage for Reliability Reporting Purposes filed by Duquesne Light on April 30, 2026 for the storm event that occurred in Duquesne Light Company's service territory on Friday, March 13, 2026.

Should you require additional information, please contact me at (412) 393-8324.

Sincerely,

A handwritten signature in blue ink that reads "Wesley Terek". The signature is written in a cursive, flowing style.

Wesley Terek, P.E.
General Manager, System Planning & Protection

cc: Dan Searfoorce
Derek Ruhl
John Van Zant
Clint McKinley

**Duquesne Light Company (DLC) – Response to Pennsylvania Public Utility Commission
Technical Utility Services (TUS) Data Request, Set 1**

**DLC Request for Exclusion of Major Outage for Reliability Reporting Purposes (Exclusion
Request) at Docket No. M-2026-3062162**

Response by: Wesley Terek

1. Reference DLC’s Exclusion Request

a. Please quantify the total Customer Minutes Interrupted related to the event.

Duquesne Light Response:

Duquesne Light continues to use kVA-based metrics until such a time as the Company files for revised, customer-based benchmarks with the PUC. The total kVA-Minutes Interrupted for the March 13, 2026 event was 1,729,561,383.

Customer Minutes Interrupted as calculated by the Duquesne Light outage management system (OMS) are available but are subject to error and should not be considered as official values. For the March 13, 2026 event, Customer Minutes Interrupted was calculated as 210,741,319.

b. Please confirm the total number of utility workers, contract workers, and workers received as mutual aid assigned specifically to the repair work as indicated in the table 4(d) provided in the Exclusion Request.

Duquesne Light Response:

Duquesne Light confirms that the total number of mutual aid workers assigned to repair work was 344 (154 GMB, 157 Northline Compass, 33 Vision), as documented in the response to M-1 within DLC’s response to the TUS data request dated March 25, 2026. “DLC’s Report of Outage Electric March 13 2026 and TUS Data Request Response – Refile 050426” and “Duquesne Light's Request for Exclusion of Major Outage 03-13-26” will both be amended and re-filed to reflect this correct count.

**Duquesne Light Company (DLC) – Response to Pennsylvania Public Utility Commission
Technical Utility Services (TUS) Data Request, Set 1**

**DLC Request for Exclusion of Major Outage for Reliability Reporting Purposes (Exclusion
Request) at Docket No. M-2026-3062162**

Verification

I, Wesley Terek, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 (relating to unsworn falsification to authorities).

Date: 6/3/26

Signed,



Wesley Terek

General Manager, System Planning & Protection